



Modern ICT/Automation Approaches for Smart Grids and Industrial Environments

Thomas I. Strasser ©

Center for Energy – Electric Energy Systems AIT Austrian Institute of Technology, Vienna, Austria

LAMBDA Summer School - SINERGY Session, June 15-16, 2021, online





Content

- > Background and Motivation
- > From Passive to Active Power Grids
- > Smart Grid ICT and Automation
- > Selexted Examples





Challenges and drivers



- Climate change
- Deep decarbonisation
- Energy transition



- Industrial competitiveness
- Business Innovation
- Digitalisation



- Urban Transformation
- Infrastructure needs
- Societal changes



› Global policy

- > Paris Agreement (COP21): long-term, limit temperature increase to 1.5°C
- > UN Sustainable Development Goals: pathway for future research and innovation activities
- > Mission Innovation: global initiative to accelerate clean energy innovation

> Europe policy

- > European Green Deal: climate-neutrality by 2050
- > EC Roadmap Low-Carbon Economy 2050: EU GHG emissions towards an 80% domestic reduction
- > EC Hydrogen Strategy and Sector Integration: renewable hydrogen electrolysers




- > Planning and operation of the energy infrastructure becomes more complex
 - Large-scale integration of renewable sources (PV, wind, etc.)
 - Controllable loads (batteries, electric vehicles, heat pumps, etc.)
- > Trends and future directions
 - › Digitalisation of power grids
 - Deeper involvement of consumers and market interaction
 - Linking electricity, gas, and heat grids for higher flexibility and resilience





- > What can be influenced in smart power distribution grids?
 - > On-load Tap Changer (OLTC) (1,2)
 - Generators (3,4)
 - Adjustable transformers (low voltage) (5)
 - > Demand Side Management (DSM) (6)







- > Planning and operation of the energy infrastructure becomes more complex
 - > Large-scale integration of renewable sources (PV, wind, etc.)
 - > Controllable loads (batteries, electric vehicles, heat pumps, etc.)
- > Trends and future directions
 - > Digitalisation of power grids
 - > Deeper involvement of consumers and market interaction
 - > Linking electricity, gas, and heat grids for higher flexibility and resilience






> Historical development and future trends










- > Interaction between different players
 - > Information exchange
 - Integration of different players/devices
 - Interaction between different players/devices






- > Smart grids on different levels
 - Transmission system (e.g., Trans-European demand/supply matching)
 - → Super Grids (offshore wind farms in northern Europe hydro storages in the Alps large scale solar/PV systems in southern Europe/Africa)
 - > Medium Voltage (MV)/Low Voltage (LV) distribution system
 - → Smart Grids (active distribution grids, integration of distributed generators and storage systems)
 - > Local energy system (e.g., for buildings or small areas; low voltage systems)
 - → Micro Grids (islanding, grid-connected)



- > What can be influenced in smart power distribution grids?
 - > On-load Tap Changer (OLTC) (1,2)
 - > Generators (3,4)
 - > Adjustable transformers (low voltage) (5)
 - > Demand Side Management (DSM) (6)






> Automation functions of smart grids

Function	Description
Self-healing	Automatic restoration of grid operation in case of faults/errors
Self-optimization	Ability to optimize the grid operation due to fluctuating renewables
Self-monitoring and diagnostics	Advanced monitoring and state estimation capability
Condition dependent maintenance	Preventive maintenance using component condition and life-time
Automatic grid (topology) reconfiguration	Automatic adjustment of the grid topology for grid optimization
Adaptive protection	Automatic adaption of protection equip. settings due to grid condition
Demand response support	Advanced energy management using distributed generation and controllable loads
Distributed management	Distributed control with automatic decision finding process and
Distributed generators with ancillary services	Possibility to use ancillary services (e.g., voltage/frequency control)
Advanced forecasting support	Forecasting of generation and load profiles for grid optimization



- > Necessary technologies
 - Internet of Energy
 - > Energy grids/infrastructure + ICT Network
 - > Bi-directional energy and communication flow
 - > Operation of Smart Grids requires innovative ICT technologies
 - > Advanced automation concepts and algorithms
 - Advanced communication concepts
 - > Intelligent grid components (inverters, controllers, meters, etc.)
 - Interoperability of systems and components (most important requirement!!!)


> Technology areas



Source: IEA



- > Intelligence on different levels
 - > System
 - > Sub-system
 - > Component
 - Sub-component





> Important ICT-based standards (IEC view)

IEC 62357

- Reference Architecture SOA
- Energy Management Systems, Distribution Management Systems

IEC 61970/ IEC 61968

- CIM (Common Information Model)
- EMS, DMS, DA, SA, DER, AMI, DR, E-Storage

IEC 61850

- Substation Automation, Power Utility Automation
- · EMS, DMS, DA, SA, DER, AMI

IEC 62351

Security

IEC 62056

Data exchange for meter reading, tariff and load control


IEC 61508

 Functional safety of electrical/electronic/programmable electronic safety-related systems



> IEC seamless integration architecture (service-oriented approach)


R






- > IEC 61970/61968 Common Information Model (CIM)
 - > Object-oriented information model of the power system
 - > Kind of domain ontology








> IEC 61850 - communication networks and systems for power utility automation









> IEC 61131 and IEC 61499 - implementation of control code

IEC 61131 Programable Logic Controller (PLC)




IEC 61499 Distributed Control System (DCS)






- > ICT-based integration architecture
 - > IEC standard-compliant
 - Virtual environment
 + real devices






- > ICT-based integration architecture
 - IEC 61850/IEC 61499 system architecture and generic communication interfaces
 - Multiple systems (SCADA/DMS, controllers, simulators)
 - Independent applications (control application(s), communication application(s))






- > DER device controller
 - > IEC 61850 communication interface
 - > IEC 61499 implementation of control algorithms
 - Usage of IEC 61850/IEC 61499 configuration interfaces for on-line adaptation of functions






- > Smart grid lab automation
 - > AIT SmartEST laboratory







- > Engineering and validation support system
 - > Model-based framework
 - > Supports engineers in the development and validation of smart grid automation applications




- > Engineering and validation support system
 - Main element:

 Power System
 Automation
 Language (PSAL)
 - Domain-specific Language (DSL) mainly based on CIM, IEC 61850 and IEC 61499

```
application VoltageControl {
   function VoltVArCtrl at DSOComputer.VoltVAr {
     requests Field.Controls fieldControls
}
   module Field {
     interface Controls {
       attribute float32 activePowerSetpoint
}}

system DistributionSystem {
   device DSOComputer {
     ethernet eth0 {ip = "10.0.0.1"}
     resource VoltVAr
   }
   router StationRouter
   generator DER

connect DSOComputer.eth0 with StationRouter
}
```






application VoltVArControlCentralized {

- > Engineering and validation support system
 - > Application example

```
function DERController at DERController.AncillaryServices {
  provides Measurements. GridMeasurements measurements
  requests DERCtrlInterfaces.DERDirectControls derDirectControls
function VoltVArController {...}
function DSCADA {...}
function DistributionRTU {...}
function DERGenerator {...}
function TransformerMonitor {...}
function BusMonitor {...}
function EndOfLineMonitor {...}
module Measurements {
  interface GridMeasurement {...}
  eventtype AggregatedMeasurement {...}
module DERCtrlInterfaces {...}
connect DERController.derDirectControls
           with DERGenerator.directControls
```



Source: AIT





> Engineering and validation support system


> System example

```
function DEScontroller at DEScontroller.AncillaryServices (
provides Measurements.GridMeasurements measurements
                                                                                                       requests DERCTFListerFaces.DEROLFectiontrols derOlfrectiontrols
system DistributionSystemVV {
                                                                                                      Function VoltyArController (.)
                                                                                                      FUNCTION DISCADA (..)
  MOER RField
                                                                                                      Georgian Distributionthy (...)
                                                                                                      Function OEMGenerator (.)
  device DERController {
                                                                                                      function TransformerMonitor [...]
                                                                                                      function BusHeritor (.)
     ethernet eth0 {ip = "10.0.0.1"}
                                                                                                      function Endofilmemonitor [...]
     ethernet eth1 {ip = "192.168.0.2"}
                                                                                                      module Resorments (
     resource AncillaryServices
                                                                                   DSO Computer
                                                                                                                                              Operation
                                                                                                                  Component
  device DSOComputer {...}
                                                                                               Volt-VAr
                                                                               D-SCADA
                                                                                               Controller
  device DistributionRTU {...}
                                                                                                                       layer
  router StationRouter
  device TransformerMonitor {...}
                                                                                                    Router
  device BusMonitor {...}
  device EndOfLineMonitor {...}
  generator ExternalSystem {...}
                                                                                RTU
  busbar MVBus {...} ...
  generator DERGenerator {
                                                                                                                      DÉR
                                                                                       Transformer
                                                                                                                                 End-of-Line
     ethernet eth0 {ip = "192.168.0.1"}
                                                                                                                   Controller
                                                                                                   Bus Monitor
                                                                                        Monitor
                                                                                                                                  Monitor
     terminal LVBus2
     resource DERResource
                                                                                                                       G
  connect DERController.eth1 with DERGenerator.eth0
   connect DERGenerator.LVBus2 with LVBus2.DERGenerator
                                                                                       Distribution
                                                                                                                                Customer
                                                                                                                                                   Source: AIT
```

application VoltVArControlCentralized (



- > Engineering and validation support system
 - Generation of IEC 61850 specifications
 - Generation of IEC 61499 code fragments





References

- [1] T. Strasser, F. Andren, J. Kathan, C. Cecati, C. Buccella, P Siano, P Leitao, G. Zhabelova, V. Vyatkin, P Vrba, V. Marik: "A Review of Architectures and Concepts for Intelligence in Future Electric Energy Systems"; IEEE Transactions on Industrial Electronics, Volume 62 (2015), Issue 4; 2424 2438.
- [2] F. Andren, R. Bründlinger, T. Strasser: "IEC 61850/61499 Control of Distributed Energy Resources: Concept, Guidelines, and Implementation"; IEEE Transactions on Energy Conversion, Volume 29 (2014), Issue 4; 1008 - 1017.
- [3] F. Pröstl Andren, T. Strasser, W Kastner: "Engineering Smart Grids: Applying Model-Driven Development from Use Case Design to Deployment"; Energies, 10 (2017).
- [4] T. Strasser, F. Andren, F. Lehfuss, M. Stifter, P. Palensky: "Online Reconfigurable Control Software for IEDs"; IEEE Transactions on Industrial Informatics, Vol. 9, August 2013 (2013), No. 3; 1455 - 1465.
- [4] M. Faschang, S. Cejka, M. Stefan, A. Frischenschlager, A. Einfalt, K Diwold, F. Pröstl Andren, T. Strasser, F. Kupzog: "Provisioning, deployment, and operation of smart grid applications on substation level: Bringing future smart grid functionality to power distribution grids"; Computer Science - Research and Development, Special Issue Paper (2016), 1 - 14.
- [5] J. Resch, B. Schuiki, S. Schöndorfer, C. Brandauer, G Panholzer, F. Pröstl Andren, T. Strasser: "Engineering and validation support framework for power system automation and control applications"; e & i Elektrotechnik und Informationstechnik, issue 8 (2020), Volume 137; 470 - 475.





www.erigrid2.eu/lab-access







Privatdoz. DI Dr. Thomas Strasser

Senior Scientist Center for Energy – Electric Energy Systems

AIT Austrian Institute of Technology GmbH Giefinggasse 2 | 1210 Vienna | Austria

T +43(o) 50550-6279 | F +43(o) 50550-6390 thomas.strasser@ait.ac.at | http://www.ait.ac.at





www.erigrid2.eu/lab-access

